



Certificate of Analysis

Cerifact Services Ltd
11 Kent House
Old Bexley Business Park
19 Bourne Road
Bexley
DA5 1LR

Sample Date: 16-Jul-14
Received Date: 16-Jul-14
Test Date : 17-Jul-14
Certificate Ref: 251280-28/07/2014 14:17:34 (2)
Certificate ID: 810547
Order Number: None Supplied
SDG Reference: CRT_FCT 17-07-14 1
Laboratory Reference: CRT_FCT[RM]1380652
Legionella Process Date: 17/07/2014

Sample : Shower Room Shwr

Details : Sample Temperature: 39.4°C

Method Ref	Determination	LOD	Result	Units
*BP50.9	Legionella spp. (Calculated)	100	N/A	cfu/l
BP50.9	Legionella spp.	100	Not Detected	cfu/Volume
*BP50.9	Volume Of Sample Filtered		500	ml

Approved By: Nasir Maroof(Laboratory Technical Manager)

Date: 27-Jul-14

Page 1 of 1

Abbreviations :< = Less than, > = Greater than. SDG = Sample Delivery Group. The results are given for the sample as received by the laboratory. The site of the test is identified by RM = Rotherham. Tests marked * have not been subcontracted and are not accredited. The Legionella (calculated) det is a calculated det where the result is extrapolated from the Legionella test results. Opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. Method details and performance characteristics are available on request.



0996