



# Certificate of Analysis

Cerifact Services Ltd  
11 Kent House  
Old Bexley Business Park  
19 Bourne Road  
Bexley  
DA5 1LR

Sample Date: 16-Jul-14  
Received Date: 16-Jul-14  
Test Date : 17-Jul-14  
Certificate Ref: 251280-28/07/2014 14:17:34 (3)  
Certificate ID: 810548  
Order Number: None Supplied  
SDG Reference: CRT\_FCT 17-07-14 1  
Laboratory Reference: CRT\_FCT[RM]1380653  
Legionella Process Date: 17/07/2014

**Sample :** Seagate Bib Tap

**Details :** **Sample Temperature:** 19.9°C

Method Ref	Determination	LOD	Result	Units
*BP50.9	Legionella spp. (Calculated)	100	N/A	cfu/l
BP50.9	Legionella spp.	100	Not Detected	cfu/Volume
*BP50.9	Volume Of Sample Filtered		500	ml

**Approved By:** Nasir Maroof(Laboratory Technical Manager)

**Date:** 27-Jul-14

Page 1 of 1

Abbreviations :< = Less than, > = Greater than. SDG = Sample Delivery Group. The results are given for the sample as received by the laboratory. The site of the test is identified by RM = Rotherham. Tests marked \* have not been subcontracted and are not accredited. The Legionella (calculated) det is a calculated det where the result is extrapolated from the Legionella test results. Opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. Method details and performance characteristics are available on request.



0996